

100% limit																		0.5		1					
Date	pH	Conductivity	Turbidity	TDS	Transmittance #	TSS	BOD5	Total P	Total N	Sodium	Potassium	Calcium	Magnesium	Boron	Sodium Absorption Ratio	Chloride	Sulfate	Chloride / Sulfate Ratio	Free Chlorine	Total Chlorine	Faecal Coliforms	Lab	Comment	Date Data Obtained	
9/07/2019	7.5	0.885	0.5	566		<2	<2	0.03	7.01	141	22	23	4.8	0.069	7	71	172	0.41	<0.05	0.05	0	CHL		17/07/2019	
23/07/2019	7.4	1.04	0.35	663		<2	<2	<0.03	8.46	163	24	27	5.6	0.084	7.4	82	243	0.34	0.08	0.59	0	CHL		5/08/2019	
6/08/2019	7.1	1.11	0.45	713		2	<2	<0.03	9.22	174	24	26	5.5	0.075	8.1	76	294	0.26	0.07	1.9	0	CHL		12/08/2019	
20/08/2019	7.4	1.17	1.6	749		2	<2	0.06	7.32	197	23	23	4.9	0.073	9.8	89	253	0.35	0.06	0.83	0	CHL		27/08/2019	
3/09/2019	7.7	1.15	0.7	733		<2	2	0.04	8.95	197	25	23	4.9	0.076	9.6	76	209	0.36	0.05	0.11	0	CHL		12/09/2019	
17/09/2019	7.9	1.27	0.5	813		2	<2	0.04	5.82	232	26	24	5.2	0.077	11.1	109	226	0.48	0.11	0.56	2	CHL		26/09/2019	
11/10/2019	7.7	1.19	0.75	764		2	<2	0.04	4.67	205	25	23	5.2	0.081	10	88	227	0.39	0.16	0.99	0	CHL		11/10/2019	
15/10/2019	7.7	1.28	0.5	817		<2	<2	0.04	4.76	228	26	23	5.2	0.074	11.2	84	239	0.35	0.23	0.44	33	CHL		24/10/2019	
29/10/2019	7.7	1.16	0.65	743		<2	<2	0.04	3.42	188	28	26	5.5	0.076	8.7	88	244	0.36	<0.05	0.27	2	CHL		6/11/2019	
12/11/2019	7.4	1.19	1.1	760		2	<2	0.03	3.63	196	28	29	5.7	0.073	8.7	108	267	0.41	0.32	0.47	0	CHL		20/11/2019	
26/11/2019	7.3	1.1	1.1	707		<2	<2	<0.03	3.64	187	30	30	6.3	0.073	8.1	93	263	0.35	<0.05	0.11	0	CHL		5/12/2019	
10/12/2019	7.2	0.971	3.2	622		7	<2	0.07	10.8	132	28	29	6.2	0.072	5.8	88	236	0.37	0.11	0.21	0	CHL		18/12/2019	
2/01/2020	7.4	1.2	3.1	768		7	<2	0.05	7.52	190	28	26	6	0.083	8.7	140	228	0.61	0.34	0.44	0	CHL		15/01/2020	
7/01/2020	7.6	1.23	3.5	786		8	3	0.06	4.82	192	29	27	5.8	0.085	8.7	144	246	0.59	<0.05	0.08	0	CHL		15/01/2020	
21/01/2020	7.4	0.84	1.9	537		4	<2	0.04	3.75	135	18	21	4.3	0.057	7.1	90	158	0.57	0.05	0.19	0	CHL		30/01/2020	
4/02/2020	8	1.12	1.8	716		5	2	0.05	3.87	202	19	22	5.4	0.069	10	105	212	0.49	<0.05	0.36	0	CHL		11/02/2020	
3/03/2020	7.4	0.775	1.4	496		2	<2	0.03	3.59	124	9.8	19	4.1	0.061	6.8	86	106	0.81	<0.05	<0.05	0	CHL		11/03/2020	
17/03/2020	8	0.912	2.5	583		5	3	0.04	8.54	157	15	19	4.7	0.065	8.4	68	122	0.55	<0.05	<0.05	0	CHL		25/03/2020	
31/03/2020	7.9	1.07	1.7	685		2	2	0.04	7.88	202	18	19	4.7	0.073	10.8	71	140	0.51	<0.05	<0.05	2	CHL		9/04/2020	
14/04/2020	8.6	0.956	0.6	612		<2	<2	0.05	4.39	170	16	24	2.3	0.069	9	69	113	0.62	<0.05	<0.05	0	CHL		22/04/2020	
12/05/2020	8.6	1.3	2.5	831		5	4	0.09	5.53	244	20	20	4.9	0.072	12.7	105	157	0.67	0.07	0.13	0	CHL		21/05/2020	
26/05/2020	8.4	1.22	1.5	781		5	3	0.06	5.18	225	21	20	5	0.077	11.5	79	145	0.55	<0.05	<0.05	0	CHL		4/06/2020	
9/06/2020	8.1	1.04	1.8	665		9	<2	0.04	5.01	166	22	23	5.3	0.075	8.1	71	168	0.42	<0.05	<0.05	0	CHL		18/06/2020	
23/06/2020	7.7	0.868	1.3	555		3	<2	0.04	4.97	128	19	23	5.2	0.062	6.3	60	136	0.44	<0.05	<0.05	0	CHL		2/07/2020	
7/07/2020	7.8	0.868	1.7	556		3	3	0.05	4.86	130	20	24	5.3	0.066	6.2	69	143	0.48	<0.01	<0.01	0	CHL		14/07/2020	
21/07/2020	7.6	0.955	0.85	611		<2	<2	0.03	5.09	140	21	25	5.5	0.071	6.6	80	186	0.43	0.2	0.4	0	CHL		29/07/2020	
4/08/2020	7.3	0.719	0.6	460		<2	<2	<0.03	3.52	99.5	16	22	5	0.059	5	62	135	0.46	0.06	0.44	0	CHL		12/08/2020	
18/08/2020	7.5	0.951	2.3	609		3	3	0.05	9.21	137	19	21	5.6	0.06	6.9	82	147	0.56	0.08	0.62	0	CHL		27/08/2020	
1/09/2020	7.5	0.969	0.7	620		3	<2	<0.03	4.54	147	19	23	5.5	0.065	7.1	77	172	0.45	0.06	0.73	0	CHL		9/09/2020	
15/09/2020	7.4	0.969	0.6	620		3	<2	<0.03	4.93	148	21	23	5.4	0.065	9.1	77	183	0.42	0.09	1.25	2	CHL		22/09/2020	
29/09/2020	7.5	1.11	1.8	713		4	<2	0.19	20.40	152	23	22	5.5	0.071	7.4	83	178	0.47	0.23	2.4	0	CHL		7/10/2020	
13/10/2020	7.5	1.1	1.9	706		5	4	0.06	17.30	163	23	24	5.6	0.070	7.8	78	195	0.4	0.09	0.38	0	CHL		21/10/2020	
27/10/2020	7.8	1.15	1.7	734		6	<2	0.08	7.78	193	24	22	5	0.071	9.7	79	190	0.42	0.06	0.06	2	CHL		4/11/2020	
10/11/2020	8.7	1.05	2.5	671		10	<2	0.07	5.34	171	24	23	5.2	0.073	8.3	80	186	0.43	0.13	0.52	0	CHL		18/11/2020	
24/11/2020	8.9	1.1	6.6	704		16	4	0.14	5.21	179	24	20	4.8	0.082	9.3	104	196	0.53	<0.05	0.06	8	CHL		2/12/2020	
16/12/2020	9	1.11	3.2	709		11	<2	0.09	4.03	185	24	17	4.6	0.077	10.3	95	203	0.47	0.19	0.6	0	CHL		16/12/2020	
21/12/2020	7.1	0.436	1.7	279		4	<2	<0.03	3.92	58	9	17	3.8	0.040	3.3	40	70	0.57	<0.05	<0.05	0	CHL		21/12/2020	
5/01/2021	7.2	0.62	1.2	397		3	<2	<0.03	5.05	83	14	20	4.7	0.058	4.4	53	105	0.5	0.04	0.05	0	CHL		5/01/2021	
19/01/2021	7.4	0.646	2	413		<2	<2	<0.03	4.08	89	14	20	4.9	0.057	4.6	55	118	0.46	0.03	0.04	0	CHL		19/01/2021	
2/02/2021	7.8	0.84	2.3	538		7	2	0.04	4.36	117	17	21	5.4	0.061	5.9	66	165	0.4	0.02	0.05	1	CHL		2/02/2021	
16/02/2021	7.6	0.896	1.4	574		5	<2	0.05	5.70	129	20	22	5.2	0.067	6.5	76	211	0.36	<0.05	<0.05	0	CHL		16/02/2021	
2/03/2021	7	0.491	0.95	314		3	<2	0.34	3.09	64	8.8	17	3.7	0.052	3.7	48	80	0.59	<0.05	0.34	0	CHL		2/03/2021	
16/03/2021	7.2	0.688	0.85	440		5	<2	0.03	6.95	91	15	19	4.9	0.061	4.8	61	119	0.51	0.2	0.3	0	CHL		16/03/2021	
30/03/2021	7.1	0.426	1.2	272		<2	<2	<0.03	3.65	54	7.9	17	4	0.053	3.1	32	73	0.45	<0.05	<0.05	0	CHL		30/03/2021	
13/04/2021	7.3	0.538	1	344		2	<2	<0.03	2.87	72	9.4	17	4.2	0.055	4	47	90	0.52	0.63	1.13	0	CHL		13/04/2021	
27/04/2021	7.2	0.836	0.65	535		7	4	<2	<0.03	5.95	118	17	22	5.6	0.063	5.8	69	171	0.4	<0.05	<0.05	48	CHL		27/04/2021
11/05/2021	7	0.548	0.6	350		<2	<2	<0.03	4.52	74	11	16	4.1	0.050	4.2	44	101	0.44	0.04	0.08	0	CHL		11/05/2021	
25/05/2021	7.2	0.781	0.95	500		<2	<2	<0.03	7.05	117	16	20	5.1	0.056	6.1	60	151	0.4	0.03	0.26	5	CHL		25/05/2021	
8/06/2021	7.4	0.921	0.95	590		4	<2	0.03	8.50	132	19	27	5.3	0.059	6	82	149	0.55	<0.05	0.29	0	CHL		8/06/2021	
22/06/2021	7.3	0.949	0.75	608		5	<2	<0.03	6.50	141	19	27	5.2	0.058	6.5	87	154	0.56	<0.05	<0.05	0	CHL		22/06/2021	
6/07/2021	7.3	0.891	0.95	570		3	<2	<0.03	5.57	133	18	23	5	0.057	6.5	69	163	0.42	<0.05	<0.05	0	CHL		6/07/2021	

100% limit																			0.5		1		
24/10/2023	7.4	0.856	2.3	548	71.7	5	<2	0.06	5.13	75	25	29	39	0.052	2.1	82	183	0.45	<0.03	0.13	0	CHL	24/10/2023
7/11/2023	7.3	0.865	1.8	554	70.7	3	6	0.12	7.6	73	24	29	47	0.074	1.9	78	162	0.48	<0.03	0.03	0	CHL	7/11/2023
21/11/2023	7.2	0.781	4.3	500	64.6	10	4	0.09	6.97	65	20	26	36	0.065	1.9	74	144	0.51	<0.03	0.03	0	CHL	21/11/2023
6/12/2023	7.4	0.793	5.6	508	66.8	8	3	0.08	6.13	71	21	26	36	0.069	2.1	73	144	0.51	<0.03	0.05	0	CHL	6/01/2023
19/12/2023	7.4	0.832	2.4	532	69.2	5	<2	<0.03	6.58	78	25	27	42	0.076	2.2	83	162	0.51	0.02	0.09	0	CHL	19/12/2023
2/01/2024	7.4	0.765	4	490	64.8	4	4	0.17	9.68	62	21	25	34	0.067	1.9	70	119	0.59	0.04	0.04	▶ 35	CHL	2/01/2024
16/01/2024	7.3	0.753	7.4	482	64.1	11	2	0.12	8.59	56	18	23	31	0.073	1.8	72	128	▶ 0.56	0.02	0.02	0	CHL	16/01/2024
30/01/2024	7.3	0.719	65.1	3.7	460	11	4	0.12	9.01	61	20	24	31	0.072	1.9	74	124	0.59	0.03	0.03	1	CHL	30/01/2024
13/02/2024	7.4	0.902	66.6	3.4	577	8	4	0.11	7.08	89	23	26	35	0.076	2.7	114	137	0.84	0.04	0.05	0	CHL	13/02/2024
27/02/2024	7.4	0.821	68.4	2.9	525	7	2	0.06	6.78	71	20	24	35	0.076	2.1	85	139	0.61	0.04	0.22	0	CHL	27/02/2024
12/03/2024	7.8	0.804	68.2	2.5	515	6	2	0.09	8.37	63	20	24	37	0.067	1.9	75	137	0.54	0.03	0.03	0	CHL	12/03/2024
26/03/2024	7.5	0.783	71.2	2	501	3	7	0.08	8.22	54	18	23	34	0.064	1.7	63	112	0.57	-	-	-	CHL	26/03/2024

90%, 100%limits		6.5-8.5	15, 30	10, 20	5, 10	0.5, 1.0	10, 20	2, 4		200, 600			
Date	Days	pH	TSS	BOD5	Oil and Grease	Total Phos	Total N	Ammonia	Chlorophyl "a"	Faecal Coliforms	E.Coli	Lab	Date Data Obtain
9/07/2019		7.5	<2	<2	<2	0.06	6.79	0.23		0	0	CHL	17/07/2019
23/07/2019		7.4	<2	<2	<2	0.03	8.72	0.02		0	0	CHL	5/08/2019
6/08/2019		7.2	2	<2	<2	<0.03	▶10.1	0.38		0	0	CHL	12/08/2019
20/08/2019		7.4	4	<2	<2	0.06	7.09	0.15		0	0	CHL	27/08/2019
3/09/2019		7.7	2	<2	<2	0.04	9.06	0.25		0	0	CHL	12/09/2019
17/09/2019		8	3	<2	<2	0.03	5.95	0.02		0	0	CHL	26/09/2019
1/10/2019		7.8	2	<2	<2	0.04	4.38	0.51		40	31	CHL	11/10/2019
15/10/2019		7.8	<2	<2	<2	0.07	4.84	0.1		0	0	CHL	24/10/2019
29/10/2019		7.8	<2	<2	<2	0.04	3.3	0.05		0	0	CHL	6/11/2019
12/11/2019		7.5	2	<2	<2	0.05	3.49	0.13		0	25	CHL	20/11/2019
26/11/2019		7.4	3	<2	<2	<0.03	3.63	0.15		0	50	CHL	5/12/2019
10/12/2019		7.3	8	3	<2	0.07	▶10.7	▶7.87		0	2	CHL	18/12/2019
2/01/2020		7.5	8	<2	<2	0.05	7.54	▶4.34		0	0	CHL	15/01/2020
7/01/2020		7.6	8	2	<2	0.06	4.66	0.64		40	43	CHL	15/01/2020
21/01/2020		7.4	10	<2	<2	0.05	3.67	0.5		0	0	CHL	31/01/2020
4/02/2020		8.1	5	3	<2	0.07	4.02	0.08		0	15	CHL	11/02/2020
18/02/2020		7.5	6	<2	<2	0.04	2.91	0.25		0	0	CHL	25/02/2020
3/03/2020		7.4	4	<2	<2	0.04	3.58	1.09		0	0	CHL	11/03/2020
17/03/2020		8	6	2	<2	0.04	8.58	▶2.59		0	0	CHL	25/03/2020
31/03/2020		8	3	<2	<2	0.04	7.98	0.41		0	0	CHL	9/04/2020
14/04/2020		8.4	6	3	<2	0.07	4.74	0.03		0	0	CHL	22/04/2020
28/04/2020		8.4	5	2	<2	0.07	4.73	0.04		0	0	CHL	7/05/2020
12/05/2020		▶8.6	6	4	<2	0.07	5.54	0.03		0	0	CHL	21/05/2020
26/05/2020		▶8.5	6	3	<2	0.05	5.18	0.03		0	0	CHL	4/06/2020
9/06/2020		8.1	7	<2	<2	0.04	5.12	0.03		0	0	CHL	18/06/2020
23/06/2020		7.8	2	2	<2	0.03	5	0.04		0	0	CHL	2/07/2020
7/07/2020		7.8	7	3	<2	0.06	5.19	0.06		0	0	CHL	14/07/2020
21/07/2020		7.6	3	<2	<2	0.03	5.3	0.11		0	0	CHL	29/07/2020
4/08/2020		7.3	2	<2	<2	<0.03	3.44	0.2		0	0	CHL	12/08/2020
18/08/2020		7.6	<2	<2	<2	0.05	9.16	▶5.66		0	0	CHL	27/08/2020
1/09/2020		7.6	<2	<2	<2	<0.03	4.49	0.02		0	0	CHL	9/09/2020
15/09/2020		7.4	2	<2	<2	<0.03	4.96	0.89		0	0	CHL	22/09/2020
29/09/2020		7.6	6	<2	<2	0.18	▶21.6	▶18.3		0	0	CHL	7/10/2020
13/10/2020		7.6	5	<2	<2	0.07	▶16	▶11.4		0	0	CHL	21/10/2020

90%, 100%limits	6.5-8.5	15, 30	10, 20	5, 10	0.5, 1.0	10, 20	2, 4	200, 600				
27/10/2020	7.8	5	<2	<2	0.07	7.67	1.22	0	0	CHL	4/11/2020	
10/11/2020	▶ 8.7	12	<2	<2	0.07	5.19	0.03	0	0	CHL	18/11/2020	
24/11/2020	▶ 9.1	▶ 17	3	<2	0.11	5.1	0.04	0	0	CHL	2/12/2020	
8/12/2020	▶ 9	13	<2	<2	0.09	3.88	0.04	0	0	CHL	16/12/2020	
21/12/2020	7.2	<2	<2	<2	<0.03	4	0.15	TNTC* >250	461	CHL	21/12/2020	
5/01/2021	7.2	7	<2	<2	0.03	5.29	1.36	0	0	CHL	5/01/2021	
19/01/2021	7.4	<2	<2	<2	<0.03	4.2	0.05	0	0	CHL	19/01/2021	
2/02/2021	7.9	5	<2	<2	0.03	4.34	0.03	1	1	CHL	2/02/2021	
16/02/2021	7.6	2	<2	<2	0.03	5.76	0.04	0	0	CHL	16/02/2021	
2/03/2021	7.1	4	<2	<2	<0.03	3.28	0.27	0	0	CHL	2/03/2021	
16/03/2021	7.3	<2	<2	<2	<0.03	6.78	1.72	0	0	CHL	16/03/2021	
30/03/2021	7.1	4	<2	<2	<0.03	3.66	0.03	0	0	CHL	30/03/2021	
13/04/2021	7.3	4	<2	<2	<0.03	2.89	<0.02	0	0	CHL	13/04/2021	
27/04/2021	7.2	3	<2	<2	<0.03	5.99	0.02	0	0	CHL	27/04/2021	
11/05/2021	7	<2	<2	<2	<0.03	4.59	0.33	0	0	CHL	11/05/2021	
25/05/2021	7.3	<2	<2	<2	<0.03	7.23	0.03	1	0	CHL	25/05/2021	
8/06/2021	7.3	6	<2	<2	0.03	8.37	0.99	0	0	CHL	8/06/2021	
22/06/2021	7.4	6	<2	<2	<0.03	6.74	0.26	0	0	CHL	22/06/2021	
6/07/2021	7.4	2	<2	<2	<0.03	5.58	0.14	1	0	CHL	6/07/2021	
20/07/2021	7.5	2	<2	<2	<0.03	5.06	0.32	0	1	CHL	20/07/2021	
3/08/2021	7.4	3	<2	<2	<0.03	5.17	0.05	0	0	CHL	3/08/2021	
17/08/2021	7.5	4	<2	<2	<0.03	4.5	0.02	0	0	CHL	17/08/2021	
31/08/2021	7.6	4	<2	<2	<0.03	4.6	0.02	0	0	CHL	31/08/2021	
14/09/2021	7.8	<2	<2	<2	<0.03	4.51	0.02	0	0	CHL	14/09/2021	
28/09/2021	7.7	<2	<2	<2	0.03	5.22	0.03	0	1	CHL	28/09/2021	
12/10/2021	7.6	3	<2	<2	<0.03	5.22	0.05	0	0	CHL	12/10/2021	
26/10/2021	7.5	<2	<2	<2	0.03	5.34	0.31	0	0	CHL	26/10/2021	
9/11/2021	8	2	<2	<2	<0.03	5.49	0.04	0	0	CHL	9/11/2021	
23/11/2021	8.1	2	<2	<2	<0.03	5.34	0.08	0	0	CHL	23/11/2021	
7/12/2021	7.4	3	<2	<2	<0.03	4.65	0.35	0	0	CHL	7/12/2021	
21/12/2021	7.9	4	<2	<2	<0.03	3.9	0.07	0	32	CHL	21/12/2021	
4/01/2022	7.6	6	<2	<2	<0.03	5.04	0.03	0	0	CHL	4/01/2022	
19/01/2022	7.1	<2	<2	<2	<0.03	4.78	0.06	0	0	CHL	19/01/2022	
1/02/2022	7.2	3	<2	<2	<0.03	4.71	0.06	0	0	CHL	1/02/2022	
15/02/2022	7.5	2	<2	<2	<0.03	4.99	0.09	0	0	CHL	15/02/2022	
15/03/2022	7	<2	<2	<2	0.04	4.66	0.03	137	19	CHL	15/03/2022	
29/03/2022	7.6	2	<2	<2	0.06	4.64	0.54	0	0	CHL	29/03/2022	
12/04/2022	7.2	4	<2	<2	0.05	3.6	0.05	0	0	CHL	12/04/2022	
26/04/2022	7	2	<2	<2	<0.03	4.1	1.37	0	0	CHL	26/04/2022	
10/05/2022	7.2	<2	<2	<2	<0.03	4.82	0.12	0	0	CHL	10/05/2022	

90%, 100%limits	6.5-8.5	15, 30	10, 20	5, 10	0.5, 1.0	10, 20	2, 4	200, 600				
24/05/2022	7.1	6	<2	<2	0.03	5.19	0.21	0	0	CHL	24/05/2022	
7/06/2022	7.5	4	<2	<2	0.03	5.49	0.02	0	0	CHL	7/06/2022	
22/06/2022	7.3	<2	<2	<2	<0.03	5.58	<0.02	0	0	CHL	22/06/2022	
5/07/2022	7.2	<2	<2	<2	<0.03	4.97	0.04	0	0	CHL	5/07/2022	
19/07/2022	7.6	<2	<2	<2	<0.03	4.64	<0.02	0	0	CHL	19/07/2022	
2/08/2022	7.7	<2	<2	<2	<0.03	4.97	<0.02	0	0	CHL	2/08/2022	
16/08/2022	7.7	<2	<2	<2	0.03	5	<0.02	0	0	CHL	16/08/2022	
30/08/2022	8	9	2	<2	0.04	5.08	<0.02	2	0	CHL	30/08/2022	
13/09/2022	7.8	6	<2	<2	0.03	4.53	<0.02	0	0	CHL	13/09/2022	
27/09/2022	7.3	4	<2	<2	<0.03	3.8	0.16	0	1	CHL	27/09/2022	
11/10/2022	8	2	<2	<2	0.03	3.53	0.05	0	0	CHL	11/10/2022	
25/10/2022	7.5	5	<2	<2	<0.03	4.79	0.27	0	0	CHL	25/10/2022	
8/11/2022	7.9	<2	<2	<2	<0.03	3.87	0.02	0	0	CHL	8/11/2022	
22/11/2022	8	<2	<2	<2	<0.03	3.78	0.02	0	0	CHL	22/11/2022	
6/12/2022	8.1	<2	8	<2	0.03	3.57	0.02	0	0	CHL	6/12/2022	
20/12/2022	▶ 8.6	5	<2	<2	<0.03	3.97	0.03	0	0	CHL	20/12/2022	
3/01/2023	8	<2	<2	<2	0.03	6.75	0.03	0	0	CHL	3/01/2023	
17/01/2023	8.3	2	<2	<2	0.04	4.75	0.03	0	0	CHL	17/01/2023	
31/01/2023	7.6	<2	<2	<2	0.05	5.72	▶ 2.08	0	0	CHL	31/01/2023	
14/02/2023	7.6	9	5	<2	0.18	▶ 11.7	▶ 5.15	0	0	CHL	14/02/2023	
28/02/2023	7.3	<2	<2	<2	0.12	▶ 10.4	▶ 3.62	0	0	CHL	28/02/2023	
14/03/2023	7.5	<2	<2	<2	0.07	8.35	0.66	0	0	CHL	14/03/2023	
28/03/2023	7.6	3	3	<2	0.06	5.43	0.33	0	0	CHL	28/03/2023	
11/04/2023	7.6	10	2	<2	0.06	9.34	0.96	0	0	CHL	11/04/2023	
26/04/2023	7.6	7	<2	<2	0.08	▶ 11.7	1.11	2	2	CHL	26/04/2023	
9/05/2023	7.4	2	<2	<2	0.06	9.98	1.4	0	0	CHL	9/05/2023	
23/05/2023	7.4	3	3	<2	0.06	7.85	1.07	0	0	CHL	23/05/2023	
6/06/2023	7.5	2	3	<2	0.06	8.75	0.43	0	0	CHL	6/06/2023	
20/06/2023	7.5	2	2	<2	0.05	6.13	0.06	0	0	CHL	20/06/2023	
4/07/2023	7.5	<2	<2	<2	0.08	7.1	0.27	0	0	CHL	4/07/2023	
18/07/2023	7.5	2	<2	<2	0.03	7.18	0.04	0	0	CHL	18/07/2023	
1/08/2023	7.5	<2	<2	<2	0.03	6.17	0.03	0	0	CHL	1/08/2023	
15/08/2023	7.6	3	<2	<2	0.04	7.22	0.19	0	0	CHL	15/08/2023	
29/08/2023	7.7	2	<2	<2	0.1	6.97	0.08	0	0	CHL	29/08/2023	
12/09/2023	7.4	4	<2	<2	0.06	6.98	▶ 2.58	0	0	CHL	12/09/2023	
26/09/2023	7.4	4	<2	<2	0.09	6.22	▶ 2.27	0	0	CHL	26/09/2023	
10/10/2023	7.3	5	<2	<2	0.05	5.68	1.61	0	0	CHL	10/10/2023	
24/10/2023	7.5	7	2	<2	0.08	5.14	0.14	0	0	CHL	24/10/2023	

decant gate issues
with tank 1 offline-
ammonia

90%, 100%limits	6.5-8.5	15, 30	10, 20	5, 10	0.5, 1.0	10, 20	2, 4	200, 600				
7/11/2023	7.4	5	3	<2	0.22	▶12.5	▶8.35	2	4	CHL	7/11/2023	
21/11/2023	7.3	8	4	<2	0.1	7.03	0.88	0	0	CHL	21/11/2023	
6/12/2023	7.5	9	4	<2	0.09	6.26	0.13	0	1	CHL	6/12/2023	
19/12/2023	7.5	5	<2	<2	<0.03	6.69	0.11	0	0	CHL	19/12/2023	
2/01/2024	7.4	5	3	<2	0.19	▶10.2	▶5.28	14	0	CHL	2/01/2024	
16/01/2024	7.4	9	2	<2	0.11	8.35	1.69	0	0	CHL	16/01/2024	
30/01/2024	7.4	11	<2	<2	0.12	9.13	▶2.89	0	0	CHL	30/01/2024	
13/02/2024	7.5	7	2	<2	0.1	7.21	1.15	0	0	CHL	13/02/2024	
27/02/2024	7.5	6	2	<2	0.05	6.87	0.46	0	0	CHL	27/02/2024	
12/03/2024	7.8	7	3	<2	0.07	8.32	<0.02	0	29	CHL	12/03/2024	
26/03/2024	7.3	4	<2	<2	0.09	8.38	1.6	-	-	CHL	26/03/2024	