

Date	pH	Total Suspended Solids	BOD	Oil & Grease	Total Phos	Total N	NH ₃ (Ammonia)	Faecal Coliforms	E.coli	Chlorophyll "a"	Testing Lab	Comments	Date Data Obtained
13/12/2016	7.04	2.00	2.00	3.00	0.06	3.61	0.34	<1	<1	0.064	EAL		21/12/2016
10/01/2017	7.08	3.00	2.00	<2	0.07	5.89	0.41	10.00	<1	0.073	EAL		27/1/2017
24/01/2017	7.08	7.00	3.00	<2	0.14	6.84	0.14	26.00	11.00	0.164	EAL		7/02/2017
7/02/2017	7.03	5.00	4.00	<2	0.15	7.07	0.25	16.00	14.00	0.145	EAL		21/02/2017
21/02/2017	6.93	4.00	2.00	<2.0	0.17	8.63	4.00	6.00	<1	0.061	EAL		2/03/2017
7/03/2017	6.72	4.00	2.00	4.70	0.12	6.33	0.819	10.00	<1	0.041	EAL		14/03/2017
21/03/2017	6.95	12.00	1.00	2.8	0.12	5.09	0.718	104.00	70.00	0.017	EAL		29/03/2017
4/04/2017	6.99	<1	2.00	<2.0	0.11	7.08	0.599	<1	<1	0.011	EAL		12/04/2017
18/04/2017	7.04	2.00	1.00	2.00	0.11	5.45	0.571	9.00	4.00	0.025	EAL		28/04/2017
2/05/2017	6.78	2.00	1.00	3.10	0.118	5.90	0.813	5.00	<1	0.008	EAL		11/05/2017
16/05/2017	6.97	1.00	1.00	<2.0	0.11	5.00	1.41	<1	<1	0.006	EAL		23/05/2017
30/05/2017	7.04	1.00	1.00	2.00	0.08	4.72	0.807	<1	<1	0.026	EAL		8/06/2017
13/06/2017	6.65	9.00	2.00	<2	0.20	5.03	0.996	12.00	4.00	0.032	EAL		23/06/2017
27/06/2017	6.92	2.00	2.00	<2.0	0.12	6.40	0.80	<1	<1	0.015	EAL		4/07/2017
11/07/2017	6.80	4.00	<2	<2	<0.05	6.60	0.56	0.00	0.00	0.009	CHL		18/07/2017
25/07/2017	7.50	4.00	3.00	<2	0.06	6.13	4.46	0.00	0.00	<0.001	CHL		2/08/2017
8/08/2017	7.00	3.00	3.00	<2	0.03	5.82	1.79	0.00	0.00	0.010	CHL		16/08/2017
22/08/2017	7.00	3.00	<2	<2	0.04	6.53	2.68	0.00	0.00	<0.001	CHL		28/08/2017
5/09/2017	7.00	2.00	<2	<2	<0.03	5.60	1.66	0.00	0.00	0.003	CHL		15/09/2017
19/09/2017	7.10	6.00	5.00	<2	0.08	9.33	8.43	2.00	0.00	0.063	CHL		25/09/2017
3/10/2017	6.90	8.00	2.00	<2	0.07	5.68	2.07	2.00	1.00	0.012	CHL		13/10/2017
17/10/2017	6.90	2.00	2.00	<2	0.07	10.00	4.54	0.00	0.00	0.006	CHL		25/10/2017
31/10/2017	7.00	6.00	4.00	<2	0.08	6.48	1.62	2.00	1.00	0.042	CHL		7/11/2017
14/11/2017	7.00	8.00	4.00	<2	0.09	7.14	0.30	0.00	0.00	0.014	CHL		22/11/2017
28/11/2017	7.10	8.00	6.00	<2	0.13	7.31	0.70	0.00	0.00	0.024	CHL		4/12/2017
12/12/2017	7.10	5.00	4.00	<2	0.10	7.41	2.02	6.00	1.00	N/A	CHL		20/12/2017
4/01/2018	7.20	3.00	2.00	<2	0.06	6.84	3.75	40.00	10.00		CHL		15/01/2018
9/01/2018	7.00	5.00	2.00	<2	0.06	5.58	0.22	10.00	0.00		CHL		17/01/2018
23/01/2018	7.00	8.00	4.00	<2	0.07	5.73	0.12	46.00	36.00		CHL		30/01/2018
6/02/2018	7.00	5.00	3.00	<2	0.07	6.77	0.29	20.00	8.00		CHL		14/02/2018
20/02/2018	7.10	6.00	2.00	<2	0.07	5.30	1.56	1.00	1.00		CHL		1/03/2018
6/03/2018	6.90	4.00	<2	<2	0.05	4.87	0.89	57.00	22.00		CHL		15/03/2018
20/03/2018	7.00	2.00	<2	<2	0.11	5.28	0.40	150.00	135.00		CHL		27/03/2018
3/04/2018	7.00	4.00	<2	3.00	0.07	5.62	0.53	5.00	5.00		CHL		5/04/2018 & 12/4/18
17/04/2018	7.00	10.00	2.00	<2	0.06	5.44	0.34	2.00	2.00		CHL		26/04/2018
1/05/2018	7.40	7.00	<2	<2	0.10	9.08	0.68	0.00	0.00		CHL		10/05/2018
15/05/2018	6.70	5.00	2.00	<2	0.09	8.83	0.90	0.00	0.00		CHL		23/05/2018
29/05/2018	6.80	7.00	2.00	<2	0.13	6.61	0.44	0.00	0.00		CHL		4/06/2018
12/06/2018	7.00	<2	<2	<2	0.10	6.50	1.91	0.00	0.00		CHL		21/06/2018
26/06/2018	7.00	3.00	<2	<2	0.05	5.00	0.90	0.00	0.00		CHL		3/07/2018
10/07/2018	7.10	<2	<2	<2	0.07	6.84	3.10	0.00	0.00		CHL		17/07/2018
24/07/2018	7.00	4.00	<2	<2	0.07	4.87	1.25	90.00	29.00		CHL		2/08/2018

Date	pH	Total Suspended Solids	BOD	Oil & Grease	Total Phos	Total N	NH ₃ (Ammonia)	Faecal Coliforms	E.coli	Chlorophyll "a"	Testing Lab	Comments	Date Data Obtained
7/08/2018	7.10	2.00	<2	<2	0.06	5.85	1.18	0.00	0.00		CHL		16/08/2018
21/08/2018	7.10	3.00	<2	<2	0.09	4.50	1.52	0.00	0.00		CHL		28/08/2018
4/09/2018	7.20	5.00	<2	<2	0.04	5.96	3.05	2.00	0.00		CHL		11/09/2018
18/09/2018	7.20	<2	<2	<2	0.06	4.80	1.46	3.00	2.00		CHL		24/09/2018
2/10/2018	7.10	<2	<2	<2	0.08	5.52	2.30	0.00	0.00		CHL		9/10/2018
16/10/2018	7.00	6.00	2.00	<2	0.13	5.72	4.07	5.00	5.00		CHL		25/10/2018
30/10/2018	7.00	<2	<2	<2	0.07	7.86	3.72	0.00	0.00		CHL		8/11/2018
13/11/2018	7.00	4.00	<2	<2	0.06	5.37	0.90	1.00	1.00		CHL		22/11/2018
27/11/2018	7.70	2.00	<2	<2	0.06	6.53	1.09	2.00	0.00		CHL		6/12/2018
12/12/2018	7.00	8.00	3.00	<2	0.10	5.42	0.66	6.00	2.00		CHL		18/12/2018
2/01/2019	7.00	6.00	3.00	<2	0.04	5.34	0.42	5.00	3.00		CHL		10/01/2019
8/01/2019	7.00	8.00	3.00	<2	0.09	5.59	0.32	34.00	33.00		CHL		17/01/2019
22/01/2019	7.10	7.00	4.00	<2	0.13	5.18	0.50	26.00	23.00		CHL		29/01/2019
5/02/2019	7.00	4.00	5.00	<2	0.11	6.50	0.26	16.00	0.00		CHL		13/02/2019
19/02/2019	7.20	7.00	7.00	<2	0.09	5.59	0.16	0.00	0.00		CHL		28/02/2019
5/03/2019	6.60	3.00	2.00	<2	0.12	5.35	1.19	33.00	13.00		CHL		15/03/2019
19/03/2019	6.90	<2	<2	<2	0.10	7.59	0.47	9.00	2.00		CHL		28/03/2019
2/04/2019	7.00	2	<2	<2	0.2	6.57	2.61	0	0		CHL		11/04/2019
16/04/2019	6.90	2	<2	<2	0.1	7.77	1.40	3	2		CHL		2/05/2019
30/04/2019	7.00	2	<2	<2	0.2	7.98	1.34	5	0		CHL		9/05/2019
14/05/2019	7.10	<2	<2	<2	0.14	10.10	6.65	0	0		CHL		23/05/2019
28/05/2019	7.20	2	3	<2	0.3	29.20	28.80	2	0		CHL		6/06/2019
11/06/2019	6.80	10	7	<2	0.2	8.78	0.900	0	0		CHL		20/06/2019
25/06/2019	6.80	<2	<2	<2	0.1	8.06	0.800	0	2		CHL		4/07/2019
9/07/2019	6.90	<2	<2	<2	0.1	5.92	1.180	0	0		CHL		17/07/2019
23/07/2019	6.80	<2	<2	<2	0.1	5.21	1.430	0	0		CHL		
6/08/2019	6.90	2	<2	<2	0.1	5.20	1.530	0	0		CHL		14/08/2019
20/08/2019	6.80	3	<2	<2	0.1	5.04	2.760	0	0		CHL		27/08/2019
3/09/2019	7.00	5	<2	<2	0.1	5.77	3.310	0	0		CHL		12/09/2019
17/09/2019	6.80	3	<2	<2	0.1	5.02	0.870	0	0		CHL		26/09/2019
1/10/2019	7.00	6	2	<2	0.1	6.88	2.190	0	0		CHL		11/10/2019
15/10/2019	6.90	8	<2	<2	0.1	7.06	0.680	0	0		CHL		24/10/2019
29/10/2019	7.10	6	2	<2	0.1	6.58	2.430	0	0		CHL		6/11/2019
12/11/2019	7.00	4	<2	<2	0.1	5.87	0.310	0	0		CHL		20/11/2019
26/11/2019	6.90	2	<2	<2	0.1	7.03	0.530	2	0		CHL		5/12/2019
10/12/2019	7.10	5	<2	<2	0.1	8.71	0.660	2	1		CHL		18/12/2019
17/12/2019	7.20	5	<2	<2	0.1	6.97	0.280	0	0		CHL		2/01/2020
7/01/2020	7.10	5	<2	<2	0.1	9.73	0.450	3	2		CHL		15/01/2020
21/01/2020	6.90	8	<2	<2	0.1	7.58	0.540	104	110		CHL		30/01/2020
4/02/2020	7.00	9	3	<2	0.2	8.45	2.880	6	6		CHL		11/02/2020
18/02/2020	7.00	7	<2	<2	0.2	7.84	2.670	8	2		CHL		26/02/2020
3/03/2020	7.00	6	2	<2	0.1	9.68	0.260	2	0		CHL		11/03/2020

Date	pH	Total Suspended Solids	BOD	Oil & Grease	Total Phos	Total N	NH ₃ (Ammonia)	Faecal Coliforms	E.coli	Chlorophyll "a"	Testing Lab	Comments	Date Data Obtained
17/03/2020	7.00	6	3	<2	0.1	▶ 12.20	0.420	0	0		CHL		1/04/2020
31/03/2020	6.80	▶ 17	9	<2	0.4	▶ 13.50	3.900	87	46		CHL		8/04/2020
28/04/2020	7.00	5	<2	<2	0.1	8.86	0.570	0	0		CHL		7/05/2020
12/05/2020	6.90	7	4	<2	0.1	9.73	2.200	0	0		CHL		21/05/2020
26/05/2020	7.00	4	3	<2	0.1	9.87	1.940	0	0		CHL		4/06/2020
23/06/2020	7.20	6	3	<2	0.1	7.49	2.100	0	0		CHL		10/07/2020
7/07/2020	7.10	7	3	<2	0.1	8.08	4.750	0	0		CHL		16/07/2020
21/07/2020	7.10	4	<2	<2	0.1	5.76	2.750	0	0		CHL		29/07/2020
4/08/2020	7.10	3	<2	<2	0.1	5.02	1.080	0	0		CHL		12/08/2020
18/08/2020	7.00	7	<2	<2	0.1	5.64	2.140	0	0		CHL		27/08/2020
1/09/2020	7.00	4	2	<2	0.1	5.56	1.860	6	7		CHL		9/09/2020
15/09/2020	7.00	6	2	<2	0.1	6.26	1.350	0	0		CHL		22/09/2020
29/09/2020	7.00	7	4	<2	0.2	▶ 11.00	2.610	0	0		CHL		7/10/2020
13/10/2020	6.90	9	2	<2	0.1	▶ 11.20	2.210	2	4		CHL		21/10/2020
10/11/2020	7.60	10	▶ 12	<2	0.1	▶ 11.50	1.500	4	0		CHL		18/11/2020
24/11/2020	7.00	10	6	<2	0.1	7.99	0.260	182	115		CHL		2/12/2020
8/12/2020	7.20	8	4	<2	0.1	7.63	0.130	12	2		CHL		16/12/2020
21/12/2020	7.00	3	<2	<2	0.1	9.18	0.110	2	0		CHL		21/12/2020
5/01/2021	7.00	6	2	<2	0.1	▶ 12.00	0.400	3	0		CHL		5/01/2021
19/01/2021	7.00	3	2	4	0.0	7.81	0.870	5	5		CHL		19/01/2021
2/02/2021	6.90	9	2	<2	0.1	9.32	0.290	0	2		CHL		2/02/2021
16/02/2021	7.10	14	4	<2	0.1	7.86	0.570	0	2		CHL		16/02/2021
2/03/2021	7.10	6	<2	<2	0.1	7.65	0.390	16	9		CHL		2/03/2021
16/03/2021	6.90	11	3	<2	0.1	8.29	0.950	TNTC*>1000	2420		CHL		16/03/2021
30/03/2021	7.00	4	<2	<2	0.1	9.90	0.600	0	0		CHL		30/03/2021
13/04/2021	7.00	5	<2	<2	0.1	8.36	0.480	0	0		CHL		13/04/2021
27/04/2021	6.90	7	<2	<2	0.1	5.93	1.180	0	0		CHL		27/04/2021
11/05/2021	7.00	5	<2	<2	0.1	7.45	3.850	0	0		CHL		11/05/2021
25/05/2021	6.90	<2	<2	<2	0.1	6.83	0.820	0	1		CHL		25/05/2021
8/06/2021	7.00	6	3	<2	0.1	7.24	0.870	2	13		CHL		8/06/2021
22/06/2021	7.00	7	2	<2	0.1	6.10	2.390	0	0		CHL		22/06/2021
6/07/2021	7.10	4	<2	<2	0.1	4.46	0.690	0	0		CHL		6/07/2021
20/07/2021	7.00	5	<2	<2	0.1	5.43	0.710	2	0		CHL		20/07/2021
3/08/2021	6.90	5	<2	<2	0.1	4.85	1.310	0	0		CHL		3/08/2021
17/08/2021	7.10	2	<2	<2	0.1	4.67	0.740	0	0		CHL		17/08/2021
31/08/2021	7.00	5	<2	<2	0.1	4.72	1.470	0	0		CHL		31/08/2021
14/09/2021	7.40	6	▶ 13	<2	0.1	4.29	0.570	2	0		CHL		14/09/2021
12/10/2021	7.00	5	<2	<2	0.1	5.38	2.060	0	0		CHL		12/10/2021
25/10/2021	7.10	5	2	<2	0.1	4.97	1.130	3	0		CHL		25/10/2021
9/11/2021	7.00	6	2	<2	0.1	5.89	2.900	9	10		CHL		9/11/2021
23/11/2021	7.00	6	2	<2	0.1	5.19	3.020	8	5		CHL		23/11/2021
7/12/2021	7.00	6	<2	<2	0.1	5.62	1.630	5	2		CHL		7/12/2021

Date	pH	Total Suspended Solids	BOD	Oil & Grease	Total Phos	Total N	NH ₃ (Ammonia)	Faecal Coliforms	E.coli	Chlorophyll "a"	Testing Lab	Comments	Date Data Obtained
21/12/2021	6.90	5	<2	<2	0.1	5.00	0.620	1	0		CHL		21/12/2021
5/01/2022	7.20	7	<2	<2	0.1	5.61	0.960	3	2		CHL		5/01/2022
18/01/2022	6.90	2	<2	<2	0.1	6.59	0.340	3	0		CHL		18/01/2022
1/02/2022	6.90	4	2	<2	0.1	3.93	0.940	9	3		CHL		1/02/2022
15/02/2022	7.00	6	2	<2	0.0	4.46	0.870	0	3		CHL		15/02/2022
8/03/2022	6.90	5	<2	<2	0.1	4.00	1.000	6	6		CHL		8/03/2022
15/03/2022	6.50	7	<2	<2	0.1	3.60	1.200	16	6		CHL		15/03/2022
29/03/2022	7.10	5	<2	<2	0.3	6.57	5.990	10	5		CHL		29/03/2022
12/04/2022	7.10	<2	<2	<2	0.2	4.46	1.620	<2	0		CHL		12/04/2022
26/04/2022	7.00	<2	<2	<2	0.1	4.55	0.910	<2	0		CHL		26/04/2022
10/05/2022	6.90	5	<2	<2	0.1	7.19	2.160	1	1		CHL		10/05/2022
24/05/2022	7.00	5	<2	<2	0.1	5.72	1.510	<2	0		CHL		24/05/2022
7/06/2022	7.00	3	<2	<2	0.1	6.05	0.990	0	0		CHL		7/06/2022
21/06/2022	6.90	<2	<2	<2	0.1	6.77	1.800	0	0		CHL		21/06/2022
5/07/2022	6.80	4	<2	<2	0.1	7.35	2.600	0	0		CHL		5/07/2022
19/07/2022	7.10	<2	<2	<2	0.1	6.31	1.740	0	0		CHL		19/07/2022
2/08/2022	7.00	6	<2	<2	0.1	8.75	2.950	0	0		CHL		2/08/2022
16/08/2022	7.00	9	3	<2	0.2	7.45	2.990	2	0		CHL		16/08/2022
30/08/2022	6.90	8	3	<2	0.1	6.10	2.070	0	0		CHL		30/08/2022
13/09/2022	7.00	5	2	<2	0.1	8.66	4.600	0	1		CHL		13/09/2022
27/09/2022	7.00	7	3	<2	0.1	4.78	1.460	<2	4		CHL		27/09/2022
11/10/2022	7.00	5	<2	<2	0.1	6.49	3.780	0	6		CHL		11/10/2022
25/10/2022	7.00	14	<2	<2	0.2	7.23	4.240	6	10		CHL		25/10/2022
8/11/2022	6.90	2	<2	<2	0.1	7.08	1.250	0	0		CHL		8/11/2022
22/11/2022	7.00	8	5	2	0.1	8.12	2.530	0	0		CHL		22/11/2022
6/12/2022	6.90	<2	3	<2	0.1	▶11.10	4.500	32	11		CHL		6/12/2022
20/12/2022	7.10	6	<2	<2	0.1	▶14.40	6.290	0	0		CHL		20/12/2022
3/01/2023	6.90	3	3	<2	0.2	▶10.80	2.870	21	17		CHL		3/01/2023
17/01/2023	6.70	<2	2	<2	0.1	7.67	1.250	6	3		CHL		17/01/2023
31/01/2023	6.90	▶32	▶12	<2	▶1.3	▶10.90	7.920	4	6		CHL		31/01/2023
14/02/2023	6.90	8	3	<2	0.3	▶11.70	8.420	6	2		CHL		14/02/2023
28/02/2023	6.60	7	2	<2	0.1	5.71	2.000	0	0		CHL		28/02/2023
14/03/2023	7.10	13	3	<2	0.2	5.95	2.470	9	2		CHL		14/03/2023
28/03/2023	6.90	<2	3	<2	0.2	6.00	3.280	3	3		CHL		28/03/2023
11/04/2023	6.90	4	2	<2	▶0.7	8.00	1.770	14	1		CHL		11/04/2023
26/04/2023	6.90	3	3	<2	0.1	▶11.40	4.560	11	15		CHL		26/04/2023
9/05/2023	6.70	2	3	<2	0.1	7.87	1.170	0	0		CHL		9/05/2023
23/05/2023	6.80	<2	<2	<2	0.1	8.15	1.920	2	1		CHL		23/05/2023
6/06/2023	6.80	15	2	<2	0.1	6.19	1.660	0	0		CHL		6/06/2023
20/06/2023	6.80	3	3	2	0.1	6.29	1.530	0	0		CHL		20/06/2023
4/07/2023	6.70	2	<2	<2	0.1	6.98	1.600	0	1		CHL		4/07/2023
18/07/2023	6.70	3	<2	<2	0.1	7.32	2.510	0	0		CHL		18/07/2023

Date	pH	Total Suspended Solids	BOD	Oil & Grease	Total Phos	Total N	NH ₃ (Ammonia)	Faecal Coliforms	E.coli	Chlorophyll "a"	Testing Lab	Comments	Date Data Obtained
1/08/2023	6.90	5	3	<2	0.1	6.51	1.980	0	0		CHL		1/08/2023
15/08/2023	6.80	5	3	<2	0.1	7.29	1.360	2	0		CHL		15/08/2023
29/08/2023	6.90	6	2	<2	0.1	5.50	2.000	<2	0		CHL		29/08/2023
12/09/2023	6.50	8	3	<2	0.1	5.81	1.320	4	3		CHL		12/09/2023
26/09/2023	6.80	4	3	<2	0.1	7.37	1.010	23	22		CHL		26/09/2023
10/10/2023	6.70	<2	2	<2	0.1	11.30	1.060	0	0		CHL		10/10/2023
24/10/2023	6.90	5	2	2	0.1	4.72	1.250	<2	0		CHL		24/10/2023
7/11/2023	6.70	4	2	<2	0.2	6.74	4.180	0	0		CHL		7/11/2023
21/11/2023	6.70	5	2	<2	0.1	9.11	0.650	17	0		CHL		21/11/2023
5/12/2023	6.90	6	3	<2	0.1	6.90	0.570	17	1		CHL		5/12/2023
19/12/2023	6.80	7	<2	<2	0.1	7.29	1.210	25	2		CHL		19/12/2023
2/01/2024	6.90	<2	<2	<2	0.1	8.82	0.940	36	3		CHL		2/01/2024
16/01/2024	6.90	33	12	<2	1.1	11.40	6.960	11000	TNTC * >2420		CHL		16/01/2024
30/01/2024	6.90	7	3	<2	0.1	7.85	1.420	2	6		CHL		30/01/2024
13/02/2024	6.80	7	3	<2	0.3	8.02	4.150	45	205		CHL		13/02/2024